

序号	报告编号	发布日期	结论	影像资料
20	GX-B1311/21-4-23034	2023. 4. 10	对回转窑筒体每隔一米共抽取了304个点进行超声测厚，在3.5m-6点处实测最小厚度为26.21mm。	
21	GX-B1311/21-4-23035	2023. 4. 10	对回转窑筒体每隔一米共抽取了240个点进行超声测厚，在58.5m-6点处实测最小厚度为30.81mm。	
22	GX-B1310/21-4- 23039	2023. 4. 10	符合标准要求	
23	GX-B1427/21-4- 23040	2023. 4. 10	无缺陷磁痕显示	

24	GX-B1354/20-4-23004	2023. 4. 1	电网接地电容电流符合规定	
25	GX-B1306/21-4-23015	2023. 4. 11	所检项目合格	
26	GX-B1306/21-4-23016	2023. 4. 12	所检项目合格	
27	GX-B1306/21-4-23017	2023. 4. 11	所检项目合格	

28	GX-B1352/21-4-23163~23190	2023. 4. 11	本次共检矿用防爆低压交流真空馈电开关28台, 28台所检项目合格。	
29	GX-B1352/21-4-23191~23221	2023. 4. 11	本次共检矿用防爆低压交流真空馈电开关31台, 31台所检项目合格。	
30	GX-B1352/21-4-23222~23233	2023. 4. 11	本次共检矿用防爆低压交流真空馈电开关12台, 12台所检项目合格。	
31	GX-B1415/22-4-23006	2023. 4. 11	综合判定: 合格	

32	GX-B1495/20-4-23170~23176	2023/4/12	本次共检高压防爆开关7台，7台所检项目合格。	
33	GX-B1495/20-4-23177~23186	2023/4/12	本次共检高压防爆开关10台，10台所检项目合格。	
34	GX-B1495/20-4-23187~23203	2023/4/12	本次共检高压开关柜17台，17台所检项目合格。	
35	GX-B1323/21-4-23065~23067	2023/4/12	本次共检三相交流电动机3台，3台三相交流电动机所检项目合格。	

36	GX-B1404/20-4-23001	2023. 4. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
37	GX-B1404/20-4-23002	2023. 4. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
38	GX-B1404/20-4-23003	2023. 4. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
39	GX-B1404/20-4-23004	2023. 4. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	

40	GX-B1499/21-4-23014	2023. 4. 12	所检项目合格	
41	GX-B1499/21-4-23015	2023. 4. 12	所检项目合格	
42	GX-B1499/21-4-23016	2023. 4. 12	所检项目合格	
43	GX-B1499/21-4-23017	2023. 4. 12	所检项目合格	

44	GX-B1499/21-4-23018	2023. 4. 12	所检项目合格	
45	GX-B1499/21-4-23019	2023. 4. 12	所检项目合格	
46	GX-B1499/21-4-23020	2023. 4. 12	所检项目合格	
47	GX-B1499/21-4-23021	2023. 4. 12	所检项目合格	

48	GX-B1308/21-4-23002	2023. 4. 12	所检项目合格	
49	GX-B1359/21-4-23074~23084	2023. 4. 12	所检项目合格	
50	GX-B1359/21-4-23085~23094	2023. 4. 13	所检项目合格	
51	GX-B1310/21-4-23032	2023. 4. 13	符合标准要求	

52	GX-B1310/21-4-23033	2023. 4. 13	符合标准要求	
53	GX-B1310/21-4-23041	2023. 4. 13	未发现超过Φ2mm当量直径缺陷	
54	GX-B1517/20-4-23018	2023. 4. 13	综合判定：合格	
55	GX-B1312/20-4-23057~23059	2023. 4. 14	本次共检电力变压器3台，3台所检项目合格。	

56	GX-B1312/20-4-23060~23064	2023. 4. 14	本次共检电力变压器5台，5台所检项目合格。	
57	GX-B1312/20-4-23172~23173	2023. 4. 14	本次共检电力变压器2台，2台所检项目合格。	
58	GX-B1314/21-4-23011~23013	2023. 4. 14	本次共检验煤矿在用干式电抗器3台，3台所检项目合格。	
59	GX-B1321/20-4-23102~23105	2023. 4. 14	本次共检电力电缆4条，4条电力电缆所检项目合格。	

60	GX-B1321/20-4-23106~23112	2023. 4. 14	本次共检电力电缆7条，7条电力电缆所检项目合格。	
61	GX-B1321/20-4-23191~23195	2023. 4. 14	本次共检电力电缆5条，5条电力电缆所检项目合格。	