

序号	报告编号	发布日期	结论	影像资料
170	GX-B1451/20-2-23079~23096	2023. 3. 28	本次共检高压开关柜18台，18台所检项目合格。	
171	GX-B1451/20-2-23097~23102	2023. 3. 28	本次共检高压开关柜6台，6台所检项目合格。	

172	GX-B1311/21-2-23001	2023. 3. 31	<p>Φ426×12无缝 钢管实测最小壁厚为 6.64mm。</p>	
173	GX-B1311/21-2-23002	2023. 3. 31	<p>Φ426×12无缝 钢管实测最小壁厚为 6.81mm。</p>	
174	GX-B1322/21-2-23036~23040	2023. 3. 31	<p>本次共检验电力电 缆5条，5条所检项目 合格。</p>	