

序号	报告编号	发布日期	结论	影像资料
62	GX-B1404/20-4-23007	2023. 4. 14	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求。	
63	GX-B1404/20-4-23008	2023. 4. 14	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求。	
64	GX-B1358/21-4-23003	2023. 4. 14	所检项目合格	

65	GX-B1350/21-4-23016	2023. 4. 18	所检项目合格		 <p>2023. 3. 18</p>	
66	GX-B1350/21-4-23017	2023. 4. 18	所检项目合格		 <p>2023. 3. 19</p>	
67	GX-B1350/21-4-23018	2023. 4. 18	所检项目合格		 <p>2023. 3. 20</p>	
68	GX-B1350/21-4-23023	2023. 4. 18	所检项目合格		 <p>2023. 3. 23</p>	

69	GX-B1350/21-4-23024	2023. 4. 18	所检项目合格	
70	GX-B1328/20-4-23083	2023. 4. 18	本次共检绝缘手套4只，4只所检项目合格。	
71	GX-B1328/20-4-23084	2023. 4. 18	本次共检绝缘鞋4只，4只所检项目合格。	
72	GX-B1328/20-4-23067	2023. 4. 18	本次共检绝缘手套24只，24只所检项目合格。	

73	GX-B1328/20-4-23068	2023. 4. 18	本次共检绝缘鞋24只，24只所检项目合格。	
74	GX-B1352/21-4-23234~23246	2023. 4. 18	所检项目合格	
75	GX-B1352/21-4-23247~23274	2023. 4. 18	所检项目合格	
76	GX-B1352/21-4-23275~23291	2023. 4. 18	所检项目合格	

77	GX-B1354/20-4-23006	2023. 4. 18	所检项目合格	 <p>2023. 3. 12</p>
78	GX-B1352/21-4-235019~235021	2023. 4. 18	所检项目合格	 <p>2023. 3. 19</p>