



序号	报告编号	发布日期	结论	影像资料
363	GX-B1404/20-5-23016	2023. 5. 28	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
364	GX-B1404/20-5-23017	2023. 5. 28	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
365	GX-B1404/20-5-23018	2023. 5. 28	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	

366	GX-B1404/20-5-23019	2023. 5. 28	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
367	GX-B1321/20-5-23639~23644	2023/5/29	本次共检电力电缆6条，6条电力电缆所检项目合格。	
368	GX-B1312/20-5-23356~23359	2023/5/29	本次共检电力变压器4台，4台电力变压器所检项目合格。	

369	GX-B1321/20-5-23635~23638	2023/5/29	本次共检电力电缆4条，4条电力电缆所检项目合格。	 <p>2023/4/1</p>
370	GX-B1312/20-5-23361~23367	2023/5/29	本次共检电力变压器7台，7台电力变压器所检项目合格。	 <p>2023/4/1</p>
371	GX-B1495/20-5-23903~23912	2023/5/29	本次共检高压开关柜10台，10台高压开关柜所检项目合格。	 <p>2023/4/4</p>

372	GX-B1308/21-5-23018	2023/5/26	所检项目合格。	
373	GX-B1499/21-5-23058	2023/5/26	所检项目合格。	
374	GX-B1499/21-5-23059	2023/5/26	所检项目合格。	

375	GX-B1499/21-5-23060	2023/5/26	所检项目合格。	
376	GX-B1308/21-5-23019	2023/5/26	所检项目合格。	
377	GX-B1499/21-5-23061	2023/5/26	所检项目合格。	

378	GX-B1499/21-5-23062	2023/5/26	所检项目合格。	
379	GX-B1499/21-5-23063	2023/5/26	所检项目合格。	
380	GX-B1308/21-5-23020	2023/5/26	所检项目合格。	

381	GX-B1499/21-5-23064	2023/5/26	所检项目合格。	
382	GX-B1499/21-5-23065	2023/5/26	所检项目合格。	
383	GX-B1499/21-5-23066	2023/5/26	所检项目合格。	

384	GX-B1417/22-5-23017	2023. 5. 29	综合判定：合格。	
385	GX-B1417/22-5-23018	2023. 5. 29	综合判定：合格。	
386	GX-B1417/22-5-23019	2023. 5. 29	综合判定：合格。	

387	GX-B1417/22-5-23020	2023. 5. 29	综合判定：合格。	
388	GX-B1495/20-5-23913	2023/5/29	所检项目合格。	
389	GX-B1495/20-5-23914~23924	2023/5/29	本次共检高压防爆开关11台，11台高压防爆开关所检项目合格。 。	

390	GX-B1308/21-5-23023 23024	2023. 5. 30	所检项目合格	
391	GX-B1416/22-5-23023	2023/5/30	综合判定：合格。	
392	GX-B1312/20-5-23286~23287	2023. 5. 31	本次共检电力变压器 2台，2台电力变压器 所检项目合格。	

393	GX-B1305/21-5-23004	2023/5/31	综合判定：合格。			
394	GX-B1500/21-5-23093	2023/5/31	综合判定：合格。			
395	GX-B1500/21-5-23094	2023/5/31	综合判定：合格。			

396	GX-B1500/21-5-23095	2023/5/31	综合判定：合格。		 <p>2023/4/24</p>	
397	GX-B1309/21-5-23022	2023/5/31	综合判定：合格。		 <p>2023/4/24</p>	
398	GX-B1312/20-5-23228~23233	2023/5/31	本次共检电力变压器6台，6台电力变压器所检项目合格。		 <p>2023/4/3</p>	

399	GX-B1301/21-5-23003	2023. 5. 31	综合判定：合格。	 
400	GX-B1312/21-5-23173	2023/5/31	所检项目合格。	