

序号	报告编号	发布日期	结论	影像资料
1	GX-B1304/21-2-24006	2024. 6. 1	综合判定：合格。	
2	GX-B1304/21-2-24009	2024. 6. 1	综合判定：合格。	
3	GX-B1304/21-2-24010	2024. 6. 1	综合判定：合格。	

4	GX-B1598/21-2-24120	2024. 6. 1	实测钢丝绳有效截面积损失百分比最大为1.73%，小于5%为正常。	
5	GX-B1598/21-2-24121	2024. 6. 1	实测钢丝绳有效截面积损失百分比最大为1.67%，小于5%为正常。	
6	GX-B1598/21-2-24122	2024. 6. 1	实测钢丝绳有效截面积损失百分比最大为1.42%，小于5%为正常。	


7	GX-B1598/21-2-24123	2024. 6. 1	实测钢丝绳有效截面积损失百分比最大为1.94%，小于5%为正常。	
8	GX-B1598/21-2-24124	2024. 6. 1	实测钢丝绳有效截面积损失百分比最大为1.04%，小于5%为正常。	
9	GX-B1598/21-2-24125	2024. 6. 1	实测钢丝绳有效截面积损失百分比最大为1.33%，小于5%为正常。	

10	GX-B1598/21-2-24126	2024. 6. 1	实测钢丝绳有效截面积损失百分比最大为1.17%，小于5%为正常。	
11	GX-B1598/21-2-24127	2024. 6. 1	实测钢丝绳有效截面积损失百分比最大为1.21%，小于5%为正常。	
12	GX-B1416/22-2-24008	2024. 6. 1	综合判定：合格。	

13	GX-B1416/22-2-24009	2024. 6. 1	综合判定：合格。	
14	GX-B1416/22-2-24010	2024. 6. 1	综合判定：合格。	
15	GX-B1416/22-2-24011	2024. 6. 1	综合判定：合格。	

16	GX-B1416/22-2-24012	2024. 6. 1	综合判定：合格。	
17	GX-B1416/22-2-24013	2024. 6. 1	综合判定：合格。	
18	GX-B1416/22-2-24007	2024/6/1	综合判定：合格	

19	GX-B1416/22-2-24015	2024/6/1	综合判定：合格	 <p>2024/04/19</p>
20	GX-B1304/21-2-24012	2024. 6. 1	综合判定：合格	 <p>2024/05/23</p>
21	GX-B1301/23-2-24001	2024. 6. 1	综合判定：合格	 <p>2024/05/23</p>

22	GX-B1301/23-2-24002	2024. 6. 1	综合判定：合格	
23	GX-B1328/20-2-24061	2024/6/4	所检项目合格	
24	GX-B1328/20-2-24062	2024/6/4	所检项目合格	

25	GX-B1328/20-2-24063	2024/6/4	所检项目合格	
26	GX-B1310/21-2-24147	2024. 6. 4	符合标准要求	
27	GX-B1310/21-2-24148	2024. 6. 4	符合标准要求	

28	GX-B1310/21-2-24149	2024. 6. 4	符合标准要求	
29	GX-B1310/21-2-24150	2024. 6. 4	符合标准要求	
30	GX-B1310/21-2-24151	2024. 6. 4	符合标准要求	

31	GX-B1310/21-2-24152	2024. 6. 4	符合标准要求	
32	GX-B1310/21-2-24153	2024. 6. 4	符合标准要求	
33	GX-B1310/21-2-24154	2024. 6. 4	符合标准要求	

34	GX-B1310/21-2-24155	2024. 6. 4	符合标准要求	
35	GX-B1427/21-2-24149	2024. 6. 4	符合标准要求	
36	GX-B1427/21-2-24152	2024. 6. 4	符合标准要求	

37	GX-B1427/21-2-24155	2024. 6. 4	符合标准要求	 <p>2024/05/24</p>
38	GX-B1415/22-2-24008	2024/6/4	综合判定：合格。	 <p>2024-04-19</p>
39	GX-B1574/20-2-24001	2024. 6. 3	所检项目合格。	 <p>2024/05/12</p>

40	GX-B1574/20-2-24002	2024. 6. 3	所检项目合格。	
41	GX-B1574/20-2-24003	2024. 6. 3	所检项目合格。	
42	GX-B1574/20-2-24004	2024. 6. 3	所检项目合格。	

43	GX-B1574/20-2-24005	2024. 6. 3	所检项目合格。		
44	GX-B1574/20-2-24006	2024. 6. 3	所检项目合格。		
45	GX-B1574/20-2-24007	2024. 6. 3	所检项目合格。		

46	GX-B1574/20-2-24008	2024. 6. 3	所检项目合格。	
47	GX-B1321/20-2-24166~24179	2024. 6. 4	本次共检电力电缆14条，14条电力电缆所检项目合格。	
48	GX-B1321/20-2-24180~24190	2024. 6. 4	本次共检电力电缆11条，11条电力电缆所检项目合格。	

49	GX-B1321/20-2-24191~24195	2024. 6. 4	本次共检电力电缆5条，5条电力电缆所检项目合格。	
50	GX-B1321/20-2-24199~24210	2024. 6. 4	本次共检电力电缆12条，12条电力电缆所检项目合格。	
51	GX-B1321/20-2-24211~24220	2024. 6. 4	本次共检电力电缆10条，10条电力电缆所检项目合格。	

52	GX-B1321/20-2-24221~24228	2024. 6. 4	本次共检电力电缆8条，8条电力电缆所检项目合格。	
53	GX-B1321/20-2-24229~24230	2024. 6. 4	本次共检电力电缆2条，2条电力电缆所检项目合格。	
54	GX-B1495/20-2-24319	2024. 6. 3	所检项目合格。	

55	GX-B1495/20-2-24228~24240	2024. 6. 3	本次共检防爆型高压配电装置13台，13台所检项目合格。 。		
56	GX-B1495/20-2-24241~24252	2024. 6. 3	本次共检防爆型高压配电装置12台，12台所检项目合格。 。		
57	GX-B1495/20-2-24253~24264	2024. 6. 3	本次共检防爆型高压配电装置12台，12台所检项目合格。 。		

58	GX-B1495/20-2-24197~24211	2024. 6. 5	本次共检防爆型高压配电装置15台，15台所检项目合格。 。	
59	GX-B1495/20-2-24212~24214	2024. 6. 5	本次共检防爆型高压配电装置3台，3台所检项目合格。	
60	GX-B1495/20-2-24215~24223	2024. 6. 5	本次共检防爆型高压配电装置9台，9台所检项目合格。	