












序号	报告编号	发布日期	结论	影像资料
103	GX-B1300/23-2-24005	2024. 6. 20	综合判定：合格。	 <p>2024/05/07</p>
104	GX-B1421/20-2-24247~24248	2024. 6. 20	本次共检验电力电缆 2条,2条所检项目合格。	
105	GX-B1416/22-2-24014	2024. 6. 20	综合判定：合格。	 <p>2024/05/04</p>




106	GX-B1499/23-2-24064	2024. 6. 18	除吨水百米电耗不合格外，其余所检项目合格。	
107	GX-B1499/23-2-24065	2024. 6. 18	除吨水百米电耗不合格外，其余所检项目合格。	
108	GX-B1499/23-2-24066	2024. 6. 18	除吨水百米电耗不合格外，其余所检项目合格。	

109	GX-B1499/23-2-24067	2024. 6. 18	除吨水百米电耗不合格外，其余所检项目合格。	 <p>2024/5/28</p>
110	GX-B1499/23-2-24068	2024. 6. 18	除吨水百米电耗不合格外，其余所检项目合格。	 <p>2024/5/28</p>
111	GX-B1574/20-2-24009	2024. 6. 17	所检项目合格。	 <p>2024/5/14</p>

112	GX-B1574/20-2-24010	2024. 6. 17	所检项目合格。	 2024/5/14
113	GX-B1574/20-2-24011	2024. 6. 17	所检项目合格。	 2024/5/14
114	GX-B1574/20-2-24012	2024. 6. 17	所检项目合格。	 2024/5/14

115	GX-B1574/20-2-24013	2024. 6. 17	所检项目合格。	 2024/5/14
116	GX-B1574/20-2-24014	2024. 6. 17	所检项目合格。	 2024/5/15
117	GX-B1574/20-2-24015	2024. 6. 17	所检项目合格。	 2024/5/15


118	GX-B1574/20-2-24016	2024. 6. 17	所检项目合格。	 2024/5/15
119	GX-B1574/20-2-24017	2024. 6. 17	所检项目合格。	 2024/5/16
120	GX-B1574/20-2-24018	2024. 6. 17	所检项目合格。	 2024/5/16

121	GX-B1574/20-2-24019	2024. 6. 17	所检项目合格。		
122	GX-B1574/20-2-24020	2024. 6. 17	所检项目合格。		
123	GX-B1574/20-2-24021	2024. 6. 17	所检项目合格。		

124	GX-B1534/20-2-24012	2024. 6. 21	所检项目合格。	
125	GX-B1534/20-2-24013	2024. 6. 21	所检项目合格。	
126	GX-B1534/20-2-24014	2024. 6. 21	所检项目合格。	

127	GX-B1534/20-2-24015	2024. 6. 21	所检项目合格。	
128	GX-B1534/20-2-24016	2024. 6. 21	所检项目合格。	
129	GX-B1534/20-2-24017	2024. 6. 21	所检项目合格。	

130	GX-B1534/20-2-24018	2024. 6. 21	所检项目合格。	
131	GX-B1336/22-2-24003~24004	2024. 6. 21	所检项目合格。	
132	GX-B1451/20-2-24289~24296	2024. 6. 21	本次共检高压开关柜 8台，8台高压开关柜所 检项目合格。	

133	GX-B1451/20-2-24297~24305	2024. 6. 21	本次共检高压开关柜 9台，9台高压开关柜所 检项目合格。	
-----	---------------------------	-------------	------------------------------------	---