

序号	报告编号	发布日期	结论	影像资料
180	GX-B1305/21-1-24014	2024. 7. 26	综合判定：合格	
181	GX-B1301/23-1-24009	2024. 7. 29	综合判定：合格	

182	GX-B1301/23-1-24008	2024. 7. 29	综合判定：合格	
183	GX-B1404/20-1-24011	2024. 7. 29	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合 GB/T 14549-1993 《电能质量 公用电网谐波》要求。	

184	GX-B1404/20-1-24012	2024. 7. 29	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合 GB/T 14549-1994 《电能质量 公用电网谐波》要求。	 A man in a blue shirt and glasses is kneeling on a light-colored floor in a server room. He is positioned next to a large grey server cabinet. A blue and black device is on the floor in front of him. A yellow and black striped caution tape is visible on the floor. A timestamp '2024/7/8' is in the bottom right corner.
185	GX-B1404/20-1-24013	2024. 7. 29	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合 GB/T 14549-1995 《电能质量 公用电网谐波》要求。	 A man in a dark blue shirt and glasses is kneeling on a light-colored floor in a server room. He is looking towards a blue and black device on the floor. To his left, there is a rack of server equipment with many blue cables. A yellow and black striped caution tape is on the floor. A timestamp '2024/7/8' is in the bottom right corner.

186	GX-B1404/20-1-24014	2024. 7. 29	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合 GB/T 14549-1996 《电能质量 公用电网谐波》要求。	 <p>2024/7/9</p>
187	GX-B1611/23-1-24003	2024/7/26	所检项目合格。	 <p>2024/7/26</p>

188	GX-B1611/23-1-24004	2024/7/26	所检项目合格。	
-----	---------------------	-----------	---------	---